

all

दिल्ली में तागु संस्था पंजीकरण अधिनियम सन् 1860

(पंजाब संशोधन) अधिनियम 1957 के अधिनियम पंजीकरण का

प्रमाणपत्र

संख्या 4585 - - सन् 1970 - 1971

में प्रमाणित करता है कि श्री राजारामजी इन्द्रजीवनजी

को दिल्ली के क्षेत्र राज्य क्षेत्र में तागु संस्था पंजीकरण अधिनियम सन् 1860 (पंजाब संशोधन) अधिनियम 1957 के अधिनियम मात्र पर तारोख में पंजीकृत कर लिया गया है।

यह धरे हस्ताक्षर के अधिनियम मात्र दिनांक 18-2-71 187

17703

दिल्ली (पेटे) पर जारी किया गया।

50 रुपये का मुगताह दिया गया।

संस्था पंजीकृत,
दिल्ली।

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2023/SZ/ 144

Dated 27.12.2023

FIRE SAFETY CERTIFICATE

Certified that the **General Raj's School**, located at Hauz Khas, New Delhi- 110016 comprised of two Blocks- Ground plus two upper floors and basement, ground plus three upper floors owned/occupied by General Raj's School was issued FSC by this department vide letter no. F6/DFS/MS/School/2019/SZ/2326 Dated 16-12-2019. The premises was re-inspected by officers concerned of this department on 16/02/2023 in presence of Mr. Santosh (Manager) and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the 27/02/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/02/2023 at New Delhi by

(SUNIL CHAUDHARY)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal, General Raj's School, located at Hauz Khas, New Delhi- 110016
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.